



AMCO SPECTRO

Tel. : +91-9266-69-9990

+91-9891-57-3910

AND MATERIAL TESTING LAB LLP

Lab : A-71, Group Wazirpur Industrial Area, New Delhi-110052
Web : www.testinglabindia.com, Email : amcotestinglab@gmail.com



TEST REPORT

FF : 7.8.1.1

Issued To: M/s. Holy Convent

(Senior Secondary School)
Recognised & Affiliated to C.B.S.E
Vikas Nagar, Hastal- Ranhaulla Road
(Near Bridge), New Delhi- 110059
India.

W.O No: AMCO/69/11

Report No: 25012411

Date of Issue: 30-01-2025

Date of Receipt: 24-01-2025

Party Ref. No: PV & Verbal Dated 24-01-2025

Order Confirmation Date: 24-01-2025

SAMPLE PARTICULARS

1. Sample Packaging: In Plastic bottle.
2. Sample Quantity: Approx 1 litre.
3. Lot No/Batch No: NA
4. Date of Manufacturing: NA
5. Date of Expiry: NA
6. Sample Description: One sample described by party as Water for Drinking purpose, was received for following tests only.

PAGE 1 OF 1

TESTS RESULTS

S.NO	TESTS	TEST METHODS	RESULTS	REQUIREMENTS (IS:10500-2012)	CONFORMITY
1	Odour	IS:3025 (PART 5)-18 RA: 2022	Agreeable	Agreeable	YES
2	Taste	IS:3025 (PART 7)-17 RA: 2022	Agreeable	Agreeable	YES
3	Colour, Hazen Units	IS:3025 (PART 4)-21	<5	A. 5 max as acceptable limit B. 15 max as Permissible Limit	YES
4	pH Value	IS:3025 (PART 11)-22	7.6	6.5 to 8.5	YES
5	Total Dissolved Solids, mg/l	IS:3025 (PART 16)-23	22	A. 500 max as acceptable limit B. 2000 max as permissible limit	YES
6	Turbidity, NTU	IS:3025 (PART10)-23	<1	A. 1 max as acceptable limit B. 5 max as permissible limit	YES
7	Chloride as Cl ⁻ , mg/l	IS:3025 (PART 32)-88 RA: 2019	<0.78	A. 250 max as acceptable limit B. 1000 max as permissible limit	YES
8	Calcium as Ca, mg/l	IS:3025 (PART 21)-09 RA: 2023	1.96	A. 75 max as acceptable limit B. 200 max as permissible limit	YES
9	Magnesium as Mg, mg/l	IS:3025 (PART 46)-23	1.18	A. 30 max as acceptable limit B. 100 max as permissible limit	YES
10	Total Hardness as CaCO ₃ , mg/l	IS: 3025 (Part 21)-09 RA: 2023	9.8	A. 200 max as acceptable limit B. 600 max as permissible limit	YES
11	Flouride as F ⁻ , mg/l	IS:3025 (PART 60)-23	<0.1	A. 1.0 max as acceptable limit B. 1.5 max as permissible limit	YES
12	Iron as Fe, mg/l	IS:3025 (PART 53)-03 RA: 2023	<0.1	A. 0.3 max as acceptable limit	YES
BACTERIOLOGICAL TESTS					
13	Coliform	IS: 15185-2016	Absent	Shall not be detectable in any 100ml sample	YES
14	E. Coli	IS: 15185-2016	Absent	Shall not be detectable in any 100ml sample	YES

Remark: The sample confirms to IS: 10500-2012 w.r.t to above tests only.


R. Kumar
MANAGER

HOLY CONVENT

VIKAS NAGAR HASTSAL, RANHAULLA
ROAD (NEAR BRIDGE), NEW DELHI-59

Civil / Mechanical / Chemical / NDT TESTING

Vice Principal
Holy Convent Sr. Sec. School
Vikas Nagar, New Delhi-110059



1. The Report is valid only for samples and applicable parameters. 2. Endorsement of product is neither intended nor implied. 3. Total liability of our lab is limited to the invoiced amount. 4. Samples will be destroyed after 15 days from the date of test certificate unless specified otherwise. 5. Perishable samples will be destroyed in 2 to 7 days as applicable. 6. The Report shall not be reproduced except in full without written approval of Laboratory. 7. Report refers to the sample submitted to us and not drawn by Amco Spectro and Material Testing Lab LLP unless mentioned otherwise. 8. Retesting Charges will be applicable if results are reproducible. 9. Duplicate copy will be issued on chargeable basis. 10. In case of any dispute, the jurisdiction shall be New Delhi Courts



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SINGH VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2025/D- 2307

Dated: 06/02/25

HEALTH CERTIFICATE

1. Name of the School Holy Convent Sr.Sec School.
2. School address Vikas Nagar Hastal Ranhaulla Road New Delhi -110059
3. No of shifts 01 Timing 07.30 AM TO 2.00 PM
4. No of students:- Boys 832 Girls 559 Total 1391
5. No of staff: - Male 09 Female 48 Total 57

Accommodation provide for classroom as under:-

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. not required
- Drinking water is wholesome/ not wholesome wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue

MANAGER

HOLY CONVENT

VIKAS NAGAR HASTAL RANHAULLA
ROAD (NEAR BRIDGE), NEW DELHI-59

Dy. Health Officer

West Zone

Dy Health Officer

West Zone

MED

Vice Principal

Holy Convent Sr. Sec. School
Vikas Nagar, New Delhi-110059