



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041




Water sample collected from "Holy Convent Sr. Sec. School" Vikas Nagar, Hastal - Ranhaulla road (Near Bridge), New Delhi - 110059 vide challan No-14 Dated- 16.04.2025.

S1: Bore water at above site.

THE TEST REPORT IS FOR THIS PARTICULAR WATER SA

S2: Drinking Point (RO) at above site.

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	13.06.25	13.06.25
2.	Date of Analysis	-----	--	--	16.06.25	16.06.25
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	4.2	1.0
6.	PH value	-----	6.5	8.5	7.10	6.72
7.	Electrical Conductivity	µmho/cm	--	--	2740	86.2
8.	Total dissolved solids	mg/l	500	2000	1780	56
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	730	24
11.	Total Hardness	mg/l	200	600	650	14
12.	Calcium Hardness	mg/l	--	--	440	08
13.	Magnesium Hardness	mg/l	--	--	210	06
14.	Calcium as Ca	mg/l	75	200	176	3.2
15.	Magnesium as Mg	mg/l	30	100	50.4	1.44
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	0.02	NIL
18.	Nitrate as No ₃	mg/l	45	N.R.	28	1.8
19.	Sulphate	mg/l	200	400	148	04
20.	Chloride	mg/l	250	1000	450	20
21.	Dissolved Iron	mg/l	1	N.R.	0.36	ND
22.	Fluoride	mg/l	1	1.50	0.46	0.04
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	NIL	NIL
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		39	0



REMARKS: As per tested parameters Sample S-1 cannot be used for drinking purpose whereas Sample S-2 can be used for drinking purpose.

MANAGER
HOLY CONVENT

VIKAS NAGAR, HASTSAL, RANHAULLA
ROAD (NEAR BRIDGE), NEW DELHI-59

ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-110041

BACT.

Pooja Rajput
Vice-Principal

Holy Convent Sr. Sec. School
Vikas Nagar, New Delhi-110059

A/CHEMIST



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SINGH VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2025/D- 2307

Dated: 06/02/25


HEALTH CERTIFICATE

1. Name of the School Holy Convent Sr.Sec School.
2. School address Vikas Nagar Hastal Ranhaulla Road New Delhi -110059
3. No of shifts 01 Timing 07.30 AM TO 2.00 PM
4. No of students:- Boys 832 Girls 559 Total 1391
5. No of staff: - Male 09 Female 48 Total 57


Accommodation provide for classroom as under:-


- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. not required
- Drinking water is wholesome/ not wholesome wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue



MANAGER
HOLY CONVENT
VIKAS NAGAR HASTSAL, RANHAULLA
ROAD (NEAR BRIDGE), NEW DELHI-11


Dy. Health Officer
West Zone
Dy Health Officer
West Zone


Vice Principal
Holy Convent Sr. Sec. School
Vikas Nagar, New Delhi-110059